



ALUMINUM BACK PAN w/ SEMI-RIGID INSULATION SEALED TO FRAME

SEALANT AS REQUIRED CONTS. BLUSKIN LAPPED BETWEEN ANGLE AND STARTER STRIP

SHIM AS REQUIRED TO ACCOMMODATE VARIANCES IN GRADE (INCLUDE FOAM SILL GASKET)

CONTS. 1/8" THICK ALUMINUM ANGLE FIXED TO T/O CONCRETE w 1/4x1 1/4" TAPCONS MIN. EMBEDMENT OF 1"

1" O/A THICK ROXUL INSULATION ADHERED TO 0.062" THICK ALUM. PANEL (TYP)

6mm O/A THICK SPANDREL GLASS (TYP)

BLUESKIN MEMBRANE INSTALLED OVER METAL FLASHING AND CONCRETE

CONTS. FLASHING FIXED TO FACE OF SLAB w/ 1/4" TAPCONS 24" O/C AT EACH FLOOR

WEEP HOLES AT EVERY VENT MULLION w/ INSECT SCREEN

FRAME FIXED TO T/O CONCRETE w/ 1/4x2 3/4" TAPCONS MIN. EMBEDMENT OF 1" LENGTH OF TAPCON MAY VARY TO ACHIEVE MIN. EMBEDMENT DUE TO ACTUAL SITE CINDITION

DESCRIPTION				DWN. BY	DATE
				R.P	05/05/20
				SCALE	1-1
				ALLOY	6063-T5
05/05/20	ISSUED FOR REVIEW	00		ALUGARD ALUMINUM WINDOWS AND RAILING	
DATE	REVISION	NO	BY		
111 ADVANCE BOULEVARD, BRAMPTON, ONTARIO					